

CERTIFICATE

PS/26/GEN/0115



Order no.: GZ-CERT260904454-01
Test report ref.: GZES250601066603,
 GZES250601066604

Issue date: 2026-09-03
Invalid from: 2029-05-22

License Holder:

F&F Filipowski sp.k.
 ul. Konstantynowska 79/81, 95-200 Pabianice, Poland

Manufacturing Plant(s):

0003536242

Certified Product:

Product: Gas and Carbon Monoxide Alarm
Type/Model No.: CTLG-09-R, CTLG-09, CTLG-09-W, CTLG-08, CTLG-08-R, CTLG-08-P
Trademarks: F&F
Characteristics: AC 100-240V, 50Hz, max. 5W
 Type B apparatus.
 Alarm threshold: 30 ppm (Display), 50 ppm (Alarm sound).
 Apparatus and sensor lifetime: 5 years.
 Operating temperature: -10°C ~ +55°C
 Sound level: ≥ 85 dB at 3m.
 For other details, refer to the test report.

Tested according to:

EN 50291-1:2018 + AC:2021-01
 EN 50194-1:2023

The evaluated samples of the product fulfil the requirements of the above listed standards.
 The results of this evaluation may be used by the manufacturer or his authorized agent within the European Union as basis for establishing an EC Declaration of Conformity with the requirements of Directive 2014/35/EU and affixing of the CE Marking.
 The manufacturing process has been inspected prior to certification and is subject to regular supervision by SGS Group affiliates.
 The license holder is authorized to mark the described product with the SGS Product Safety mark as shown above.

Remarks:-

Signature



Mark Lohmann
 Certification Manager

The test mark regulation is an integral part of this certificate.



Page 1 of 1

This certificate is issued by the company under its General Conditions for Certification Services accessible at http://www.sgs.com/terms_and_conditions.htm.
 Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this Certificate.

Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Certification Body for products / Zertifizierstelle für Produkte

SGS SA, 1, Place des Alpes, P.O. Box 2152, 1211 Geneva 1, Switzerland
 t: +41 22 739 91 11 • f: +41 22 739 98 86 • certificates@sgs.com • www.safety.sgs.com

